





# **SPECIFICATION**

#### GLASS SPECIFICATION

6mm CLEAR TOUGHENED LOW E 16mm BLACK SILICONE SEALED SPACER 6mm CLEAR TOUGHENED OUTER

ALL GLASS CONFORMING TO IMPACT RESISTANCE AND BREAKAGE CHARACTERISTICS OF BS6206, WITH ALL GLASS UNITS FABRICATED TO BS5713A AND IN ACCORDANCE WITH BS6262

#### FINISH SPECIFICATION

POLYESTER POWER COATED RAL 7015 MATT EXT / 9010 MATT INT POLYESTER POWER COATING, MINIMUM THICKNESS OF 40 MICRONS.

## FRAMEWORK SPECIFICATION

PRAMIEWURK SPECIFICATION

ALL ALUMINIUM EXTRUSIONS TO COMPLY WITH BS1474 AND ALUMINIUM

SHEET/PLATE TO BS EN 485, 515 & 573. TYPICALLY PROVIDED IN GRADES
6063 & 6082 (EXTRUSIONS) AND S1CH4 & NS4 (SHEET/PLATE). ALL MILD STEEL
COMPONENTS TO BE GALVANISED, ZINC COATED OR RED OXIDE PRIMED
PRIOR TO FINISH APPLICATION. ALL STAINLESS STEEL COMPONENTS
PROVIDED IN GRADE 304 STAINLESS STEEL UNLESS OTHERWISE NOTED.
EXTREME ENVIRONMENTS (INC. MARINE) MUST BE HIGHLIGHTED AT SALES
OR DESIGN STAGE.

#### HARDWARE SPECIFICATION

ALL HARDWARE TO BE SCHEDULED FOR PURPOSE, TAKING INTO CONSIDERATION BOTH ENVIRONMENT AND BIMETALLIC REACTIONS. FASTENERS TYPICALLY SUPPLIED IN GRADE AZ & A4 STAINLESS STEEL. ALL GASKETS AND TAPES TO HAVE A COMPOSITION SUITABLE FOR CLIMATIC CONDITIONS AND UV LIGHT IN ACCORDANCE WITH BS4255. SILICONES TO BE SUPPLIED AS LOW MODULUS, NEUTRAL CURE (TYPE A) IN ACCORDANCE WITH BS5889 UNLESS OTHERWISE NOTED.

## UPSTAND/APERURE SPECIFICATION

ALL UPSTANDS/APERTURES TO BE PROVIDED WITHIN A TOLERANCE OF +/10mm TO THE DIMENSIONS STATED (TAKING INTO CONSIDERATION THE
SQUARENESS OF THE STRUCTURE). ANY DIFFERING TOLERANCE
REQUIREMENTS AS INDICATED. ALL UPSTANDS/APERTURES TO BE SUITABLE
FOR SEALING WHERE INDICATED AND STRUCTURALLY ADEQUATE FOR THE
LOADS IMPOSED.

# CLIENT STANDARD PRODUCTS

CONTRACT

CONTINUE	
JOB REF	<b>♦</b> □
ISSUE A	NAME DATE
ISSUE B	NAME DATE
ISSUE C	NAME DATE
ISSUE D	NAME DATE
PLAN VIEW AND ELEVATIONS FOR 1 No. STANDARD	

MONO PITCHED ROOFLIGHT 750 x 750

CG-MP-002

ISS.